

- 1. REFER TO CCS STORMWATER PIT INSTALLATION DETAIL (M1591) FOR MINIMUM EXCAVATION BEDDING AND BACKFILL REQUIREMENTS.
- 2. FIBRE REINFORCED CONCRETE PITS SHALL BE USED FOR PROJECTS WITHIN 2KM OF COASTLINE.



DRAWING FILE LOCATION T:\AUTOCAD BLOCKS\2010+\DOUBLE GIP IN WT (M1476).dwg

COORDINATOR DESIGN B. MORIAS 30.10.23 G.FERTEKLIS
30.10.23
DRAWN
J. CURSARO
04.03.11
DESIGNED
J. CURSARO

04.03.11

STANDARD DETAILS

DOUBLE GRATED INLET PIT

1800 x 450

SCALE AS SHOWN

CITY OF CHARLES STURT

SHEET

1 of 1

TRIM No.

12/280746

DRAWING No.

M1476

D