

## GRATED INLET PIT (300 x 300)

## NOTES:

- 1. REFER TO CCS STORMWATER PIT INSTALLATION DETAIL (M1591) FOR MINIMUM EXCAVATION BEDDING AND BACKFILL REQUIREMENTS.
- 2. FIBRE REINFORCED CONCRETE PITS SHALL BE USED FOR PROJECTS WITHIN 2KM OF COASTLINE.



DRAWING FILE

T:\AUTOCAD BLOCKS\2010+\GIP-300 (M1564).dwg

COORDINATOR DESIGN B. MORIAS 10.11.23 G.FERTEKLIS
10.11.23
DRAWN
J. CURSARO
04.03.11
DESIGNED
J. CURSARO
04.03.11

STANDARD DETAILS

## GRATED INLET PIT

300 x 300

SCALE AS SHOWN

CITY OF CHARLES STU			
1 1	of	1	
RECORD 22	22/254261		
DRAWIN	G No. 11564	D	