

NOTES:

- 1. LID AND FRAME TO BE STANDARD MANUFACTURE OF TERRA FIRMA C-150 TFC 5400 1000x640 WITH 25mm LINTEL REINFORCEMENT OR SIMILAR APPROVED. REINFORCEMENTS TO BE SL.72 FABRIC UNLESS APPROVED OTHERWISE.
- 2. REFER TO CCS STORMWATER PIT INSTALLATION DETAIL (M1591) FOR MINIMUM EXCAVATION BEDDING AND BACKFILL REQUIREMENTS.
- 3. FIBRE REINFORCED CONCRETE PITS SHALL BE USED FOR PROJECTS WITHIN 2KM OF COASTLINE.



DRAWING FILE
LOCATION

TAMUTOCAD BLOCKS\2010+\SEP
SINGLE 600 WIDE UPRIGHT K&G
(M1191).dwg

COORDINATOR DESIGN B. MORIAS 30.10.23 G.FERTEKLIS 30.10.23 DRAWN MY.W 13.02.12 DESIGNED MY.W

13.02.12

STANDARD DETAIL

SINGLE SIDE ENTRY PIT

SCALE AS SHOWN

CITY OF CHARLES STURT

SHEET

1 of 1

TRIM No.

12/31022

DRAWING No.

M1191