



## SINGLE GRATED INLET PIT DETAIL

### NOTES:

1. REFER TO CCS STORMWATER PIT INSTALLATION DETAIL (M1591) FOR MINIMUM EXCAVATION BEDDING AND BACKFILL REQUIREMENTS.
2. FIBRE REINFORCED CONCRETE PITS SHALL BE USED FOR PROJECTS WITHIN 2KM OF COASTLINE.



DRAWING FILE LOCATION  
T:\AUTOCAD BLOCKS\2010+SINGLE GIP IN WT (M1477).dwg  
COORDINATOR DESIGN  
B. MORIAS  
30.10.23

EDITED  
G.FERTEKLIS  
30.10.23  
DRAWN  
J. CURSARO  
04.03.11  
DESIGNED  
J. CURSARO  
04.03.11

### STANDARD DETAILS SINGLE GRATED INLET PIT

900 x 450

SCALE AS SHOWN

CITY OF CHARLES STURT

SHEET 1 of 1

TRIM No. 12/280783

DRAWING No. M1477 E