



- 1. ENSURE THAT THE DRIVEWAY IS AT LEAST 150mm ABOVE THE WATERTABLE LEVEL AT ONE SECTION PARALLEL TO THE
- 2. COMPLY WITH DISABILITY DISCRIMINATION ACT PRINCIPLES & AS1428 TO THE MAXIMUM EXTENT. SUBMIT PROPOSED DETAILS FOR APPROVAL WHERE COMPLIANCE CANNOT READILY BE ACHIEVED.
- 3. DESIRABLE CROSSFALL IN FOOTPATH 1:40. DESIRABLE DRIVEWAY LONGITUDINAL GRADE OF 1:14, MAXIMUM PERMISSIBLE LONGITUDINAL GRADE 1:8 (REFER TO AS1428.1)
- 4. WHERE NECESSARY OR DIRECTED TO ENSURE SMOOTH TRANSITION TO EXISTING WORK, REPLACE SECTIONS OF
- 5. WHERE REQUIRED, PLACE DN40 uPVC IRRIGATION SLEEVE BEHIND BACK OF INVERT 300mm BELOW FINISHED LEVEL AND EXTEND 200mm BEYOND PAVEMENT BOTH SIDES.
- 6. MAXIMUM WIDTH OF SINGLE DRIVEWAY IS 3.2m AT BOUNDARY.
- 7. MAXIMUM WIDTH OF DOUBLE DRIVEWAY IS 5.0m AT BOUNDARY.

DRIVEWAY CROSSOVER - RESIDENTIAL (ASPHALT)



STANDARD DETAIL DRIVEWAY CROSSOVER **RESIDENTIAL (ASPHALT)** (BOWDEN / BROMPTON ONLY)

CITY OF CHARLES STURT of TRIM No 18/109775 M1540